

ANJI YIKE DECORATION MATERIAL TECHNOLOGY CO., LTD

TEST REPORT

SCOPE OF WORK

Woven vinyl flooring

REPORT NUMBER

191106006SHF-003

TEST DATE(S)

2019-11-06 - 2019-11-21

ISSUE DATE

2019-11-21


PAGES

5

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2019)

© 2019 INTERTEK



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on assigned page.
- 2.This report is invalid without authorized person's signature.
- 3.This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.
- 6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.

Test Report

Issue Date: 2019-11-21

Intertek Report No. 191106006SHF-003

Test Items, Method and Results:

Test Item: Castor chair test

Test Method: EN 985:2001 Test C

Conditioning: Condition the test specimens at $(23 \pm 2)^\circ\text{C}$ and $(50 \pm 5)\%$ relative humidity for at least 24h

Test Condition: At a temperature range of 18°C to 25°C

Load mass: 90 kg
 Test castors: Type W
 Speed of rotating platform: 20 r/min
 Speed of castor assembly: 50 r/min
 Total test revolutions: 25000 r
 Mounting of the specimen: Floating installation with click joints

Test Result:

Type of damage	Observation (Yes/No)	Verdict
Loosening, swelling or tearing of the covering	No	Pass
Delamination	No	
Flaking or delamination of foam backin	No	
Loss of cohesion and lor powdering of binder	No	
Any destruction of the material as a whole	No	

Test Photos:



After 10000r




After 25000r

Test Report

Issue Date: 2019-11-21

Intertek Report No. 191106006SHF-003

Appendix A: Sample Received Photo



Revision:

NO.	Date	Changes	Author	Reviewer
191106006SHF-003	2019-11-21	First issue	Jackie Zhou	Mason Wang